





# **PRODUCT CONFORMITY CERTIFICATE**

This is to certify that the

## MJK MagFlux 7200

Manufactured by:

### **MJK Automation ApS**

Byageren 7 2850 NÆRUM DENMARK

has been assessed by Sira Certification Service and for the conditions stated on this certificate complies with:

MCERTS Performance Standards for Water Monitoring Equipment Part 3, Version 2.4 dated February 2013

Certification Ranges :

Velocity Pipe size 0.1m/s to 10 m/s 25mm to 400mm

Project No.: Certificate No: Initial Certification: This Certificate issued: Renewal Date: 70095871 Sira MC160314/00 31 October 2016 31 October 2016 30 October 2021

Emily Alexander Deputy Certification Manager

MCERTS is operated on behalf of the Environment Agency by

### **Sira Certification Service**



Unit 6, Hawarden Industrial Park Hawarden, Deeside, CH5 3US Tel: +44 (0)1244 670 900

The MCERTS certificate consists of this document in its entirety. For conditions of use, please consider all the information within. This certificate may only be reproduced in its entirety and without change To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts







#### **Certificate Contents**

| Approved Site Application | 2 |
|---------------------------|---|
| Basis of Certification    |   |
| Product Certified         |   |
| Certified Performance     |   |
| Description               |   |
| General Notes             |   |

#### **Approved Site Application**

Any potential user should ensure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For general guidance on monitoring techniques refer to the Environment Agency Monitoring Technical Guidance Notes available at <u>www.mcerts.net</u>

The product is suitable for use, where it is appropriate, for regulated applications such as abstraction, effluent discharge, ultraviolet disinfection and industrial processing.

#### **Basis of Certification**

This certification is based on the following Test Report(s) and on Sira's assessment and ongoing surveillance of the product and the manufacturing process:

WRc Report UC12078.01 dated October 2016

#### **Product Certified**

The measuring system consists of the following parts:

- 1. Flow sensor.
- 2. Converter, with or without display.

MagFlux® Flow Meters can be installed either with the converter mounted on the flow sensor, on a wall or mounted in a panel.

This certificate applies to all instruments fitted with software version 842012 and onwards.

Certificate No : This Certificate issued : Sira MC160314/00 31 October 2016







#### **Certified Performance**

The instrument was evaluated for use under the following conditions:

Ambient Temperature Range:-10°C to +55°CInstrument IP Rating:IP67

The instrument meets MCERTS Class 1 requirements for the combined performance characteristic as specified in Table 6 of the MCERTS performance standard. Details of individual performance characteristics are summarised below:

Results are expressed as error % of certification range, unless otherwise stated.

| Test                                   | Resul |      | ssed as %<br>tion range |    | Other results   | MCERTS<br>specification      |
|--|-------|------|-------------------------|----|---|------------------------------|
|  | <0.5  | <1   | <2                      | <8 |   |                              |
| Protection against unauthorised access |       |      |                         |    | Passcode required   | Clause 3.1.2                 |
| Indicating Device                      |       |      |                         |    | The flowmeter<br>incorporates two<br>digital outputs and<br>one digital input | Clause 3.1.3                 |
| Units of measurement                   |       |      |                         |    | The flowmeter<br>records in metric<br>units                                   | Clause 3.1.6                 |
| Combined performance characteristic    |       |      |                         |    | 2.05%   | Clause 4.2.1<br>±5% Class 2  |
| Mean Error                             |       |      | -1.45                   |    |   | Clause 6.3.2<br>±4% Class 2  |
| Repeatability                          | 0.17  |      |                         |    |   | Clause 6.3.2<br>±1% Class 1  |
| Supply Voltage                         | 0.05  |      |                         |    |   | Clause 6.3.3<br>0.5% Class 1 |
| Output impedance                       | 0.13  |      |                         |    |   | Clause 6.3.4<br>0.5% Class 1 |
| Fluid Temperature                      |       | 0.95 |                         |    |   | Clause 6.3.5<br>1% Class 2   |
| Ambient temperature                    | 0.21  |      |                         |    |   | Clause 6.3.6<br>0.5% Class 1 |
| Relative humidity                      | 0.13  |      |                         |    |   | Clause 6.3.6<br>0.5% Class 1 |
| Presence of stray currents             | 0.38  |      |                         |    |   | Clause 6.3.9<br>0.5% Class 1 |
| Bi-directional flow                    |       |      | 1.49                    |    |   | Clause 6.3.13<br>4% Class 2  |

Certificate No : This Certificate issued : Sira MC160314/00 31 October 2016







| Test                              | Results expressed as % of the certification range |                 |                          |      | Other results | MCERTS<br>specification      |
|-----------------------------------|---|-----------------|--------------------------|------|---------------|------------------------------|
|                                   | <0.5  | <1              | <2                       | <8   |               |                              |
| Conduit Size                      |   |                 |                          | 4.35 | 5             | Clause 6.3.16                |
|                                   |   |                 |                          |      |               | 6.5% Class 3                 |
| Response time                     |   |                 |                          |      | 30 seconds    | Clause 6.3.19<br><30 seconds |
| Error under field test conditions |   | M<br>M<br>Prope | Clause 7.3<br>2% Class 1 |      |               |                              |
| Up time                           |   |                 |                          |      | 100%          | Clause 7.4<br>>95%           |
| Maintenance                       |   |                 |                          |      | None          | Clause 7.5<br>to be reported |

#### Description

MagFlux® Flow Sensors are available in sizes ranging from DN 15 to DN 2000, with standard construction lengths and connections.

MagFlux® Flow Meters can be installed either with the converter mounted on the flow sensor, on a wall or mounted in a panel.

#### General Notes

- 1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this Certificate. The Manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of Sira Certificates'. The design of the product certified is defined in the Sira Design Schedule V00 for certificate No. Sira MC160314/00
- 2. If certified product is found not to comply, Sira Certification Service should be notified immediately at the address shown on this certificate.
- 3. The Certification Marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of Sira Certificates'.

Certificate No : S This Certificate issued : 3

Sira MC160314/00 31 October 2016







4. This document remains the property of Sira and shall be returned when requested by the company.

Certificate No : This Certificate issued : Sira MC160314/00 31 October 2016